

FIRE NOC APPLICATION (PREVIEW)

Request No. 8000006332

TITLE	M/s
Applicant First Name	PRINCIPAL
Applicant Middle Name	PRATIBHASTHALI GYANODAYA
Applicant LastName	VIDYAPEETH SCHOOL
Select Your Noc type	Provisional
Mobile No	7869441452
Telephone No	7869441452
Email Address	4FOXENTERPRISES@GMAIL.COM
Application Date	28.07.2020

Address of Applicant

Line1	PRINCIPAL - MISS RUPALI JAIN
Line2	PRATIBHASTHALI GYANODAYA
Line3	VIDYAPEETH SCHOOL
Line3	PLOT NO. 103,104 & 116 AT VILLAGE
Select City	INDORE
STATE	Madhya Pradesh
Pincode	241015

Address of Property

Line1	Pratibhasthali Gyanodaya Vidyapeeth School
Line2	PLOT NO. 103,104 & 116 AT VILLAGE
Line3	REWATI, TEHSIL HATOD, INDORE
Select City	INDORE

Occupancy Details

Select Your Occupancy	Educational Building/ शैक्षणिक भवन
Height of Building(in Mtr)	13
Units of Plot area	51250.00 वर्ग मीटर/Sq.Mtr

[Back](#) [Submit](#)

Your Request has been submitted with the number mentioned below

Request No. 8000006332

Please preserve the mentioned number for future reference

APPENDIX-L

FORM "S"

[See RULE 87 (5)]

FIRE AUDIT REPORT

YEAR 2022-2023

To

PRATIBHASTHALI GYANODAYA VIDHYAPEETH SCHOOL  
PLOT NO. 103,104,116 VILLAGE –REWATI, TEHI-HATOD, INDORE (M.P.)

Subject- submission of Fire Report of building: PRATIBHASTHALI GYANODAYA VIDHYAPEETH SCHOOL

I, Er. Vimal Lanjewar , B.E. Fire & Safety ,Authorized Fire engineer By Urban Administration & Development Department ,Bhopal(Madhya Pradesh)have inspected your building /permission on (dated) 08/11/2022,checked all fire-fighting equipment /installation and have completed the fire audit of said building premises.

The Said Premise is More Then 1000 sq meter of area and Shorter Then 24 meter height.

Details of fire system installed area below:

Sr.no.	Particular	Available installed or not installed as per requirement	Comments for working of system (attached Details, if needed)
1	Access	Available	Sufficient Space For Fire Brigade
2	Wet Riser	Not Required	
3	Down Comer	Available installed	working
4	Hose reel	Available installed	working
5	Automatic Sprinkler system	Not Required	
6	Yard hydrant	Not Required	
7	Underground water tank	Not available	
8	Terrace tanks	Available	25000 ltr Capacity
9	Fire pump	Not Required	
10	Terrace pump	Required	
11	First Aid Fire fighting Appliances	6 KG ABC TYPE-24 4.5 KG CO2 TYPE- 12	working
12	Pressurizes System	Not Required	
13	Auto Detection System	Not Required	
14	Manually Operated Electrical Fire alarm System	Not Required	



Sr.no.	Particular	Available installed or not installed as per requirement	Comments for working of system (attached Details, if needed)
15	PA System with talk Back Facility	Not Required	
16	Emergency Light	Available	Working Condition
17	Auto D.G. Set	Inverter Available	
18	Illuminated Exit Sign	Required	
19	Means Of Escape	2 Escape Route	Open Area
20	Compartmentation	Not Required	
21	MCB/ELCAB/RCCB/MCCB	Available	
22	Firemen Switch in Lift	Not Required	
23	Hose Boxes With Delivery Hose & Branch	Required	
24	Refuse area	Not Required	
25	Any Other Installation	Null	

It is Certified That Installed Fire Fighting Appliances Are in Working Condition and Safe.

Date -08/11/2022



Er. Vimal Lanjewar

Approved by Urban Administration & Development , Bhopal